



2023/2854/EU (DATA ACT) REGULATION

INFORMATION CLAUSE

CLAUSE D'INFORMATION | CLÁUSULA DE INFORMACIÓN
CLÁUSULA DE INFORMAÇÃO | INFORMATIONEN-KLAUSEL
INFORMATIONEN-KLAUSUL | CLAUSOLA INFORMATIVA
KLAUZULA INFORMACYJNA | INFORMAČNÍ KLAUZULE
INFORMAČNÁ KLAUZULA | CLAUZĂ DE INFORMARE
ИНФОРМАЦИОННА КЛАУЗА | TÁJÉKOZTATÓ KIKÖTÉS
ИНФОРМАЦИОНА КЛАУЗУЛА | ИНФОРМАЦИОННОЕ УСЛОВИЕ
ΡΗΤΡΑ ΠΛΗΡΟΦΟΡΗΣΗΣ

www.armac-energy.eu

PRODUCT | PRODUKT

UPS ARMAC OFFICE ON-LINE PF1 3000VA LCD 8X IEC C13 METAL CASE DUST-FREE

Catalogue number:

T/3000I/PF1/DF

PRODUCER | PRODUCENT

IMPAKT S.A.

STANISŁAWA LEMA 16

62-050 MOSINA, POLAND

PRODUCT@IMPAKT.COM.PL

MADE IN PRC

EN English

- a) The UPS generates operational and diagnostic data such as: battery charge level (%), input and output voltage, load (W/%), temperatures, alarms, and backup time. Data is presented directly on the LCD display in the form of clear numerical values and messages. When using the USB/RS-232 port, the data can additionally be exported to TXT/CSV files (on average 50–100 bytes per entry, a typical log file <1 MB).
- b) The UPS generates data continuously – the LCD display updates values in real time during device operation. Values are automatically refreshed at short intervals, and in the event of alarms, messages appear immediately on the LCD screen.
- c) The UPS does not store historical data in its permanent memory. The LCD display serves only to present the current status. Data can be archived only if the user connects the UPS to a computer/server via USB/RS-232 and uses an application (e.g., PowerManager II). In such a case, the data retention period depends on the application settings and the user.
- d) The user has immediate access to all operational and diagnostic data via the LCD display on the front panel. These data are available in the form of real-time readings and alarm messages – they are not archived on the UPS itself and do not require deletion. When using additional computer software, the data can be exported to TXT/CSV files, which the user can open with standard programs (e.g., Notepad, Excel) and delete manually by removing the log files from the program directory.

PL Polish

- e) UPS generuje dane eksploatacyjne i diagnostyczne, takie jak: poziom naładowania baterii (%), napięcie wejściowe i wyjściowe, obciążenie (W/%), temperatury, alarmy oraz czas podtrzymania. Dane prezentowane są bezpośrednio na wyświetlaczu LCD w postaci czytelnych wartości liczbowych i komunikatów. W przypadku korzystania z portu USB/RS-232, dane mogą być dodatkowo eksportowane do plików TXT/CSV (średnio 50–100 bajtów na wpis, typowy plik logów <1 MB).
- f) UPS generuje dane w sposób ciągły – wyświetlacz LCD aktualizuje wartości w czasie rzeczywistym podczas pracy urządzenia. Wartości odświeżane są automatycznie w krótkich odstępach czasu, a w przypadku wystąpienia zdarzeń alarmowych komunikaty pojawiają się natychmiast na ekranie LCD.
- g) UPS nie zapisuje danych historycznych w swojej pamięci trwałej. Wyświetlacz LCD służy wyłącznie do prezentacji bieżącego stanu. Dane mogą być archiwizowane tylko wtedy, gdy użytkownik podłączy UPS do komputera/serwera przez port USB/RS-232 i wykorzysta aplikację (np. PowerManager II). W takim przypadku okres przechowywania danych zależy od ustawień aplikacji i użytkownika.
- h) Użytkownik ma natychmiastowy dostęp do wszystkich danych eksploatacyjnych i diagnostycznych poprzez wyświetlacz LCD na panelu przednim. Dane te są dostępne w formie bieżących odczytów i komunikatów alarmowych – nie podlegają archiwizacji na samym UPS i nie wymagają usuwania. W przypadku użycia dodatkowej aplikacji komputerowej dane mogą być eksportowane do plików TXT/CSV, które użytkownik może otworzyć standardowymi programami (np. Notepad, Excel) i samodzielnie usunąć poprzez skasowanie plików z katalogu programu.